

## **SECTION 6**

### **6.36 FIRELINE CONNECTIONS TO MAINS:**

Firelines supplying sprinklers shall be sized by the local fire department and the persons responsible for the structure it protects. Denver Water will not size firelines.

The fireline shall be restrained ductile iron pipe. A fireline having a domestic connection shall have a valve 2 feet from the property line on the street side of the property line as shown on Sheet 34 of the Standard Drawings. The fireline connection may also supply a domestic service line.